

The INNOVATIVE and SMALLEST

# Weather Station

ORDERING CODE	Z-WAVE FREQUENCY
ZMNHZD1	868,4 MHz
ZMNHZD2	921,4 MHz
ZMNHZD3	908,4 MHz
ZMNHZD4	869,0 MHz
ZMNHZD5	916,0 MHz
ZMNHZD8	865,2 MHz

Weather Station is used for measuring temperature, humidity, wind & rain properties and sending the measurement values to your Z-Wave network.

The Weather Station can measure 10 different values: two sets of temperature/humidity sensors, wing gauge with 5 sensors (direction, velocity, wind gust, temperature and wind chill) and a rain sensor. With the use of the included Weather Station USB KEY all 10 values (end points) are sent and rendered in your home Z-Wave network.

Qubino Weather Station Key is used for receiving Wireless data packages (from Thermo/ Hygro Sensor Ch1, Thermo/ Hygro Sensor Ch2, Rain Gauge, Wind Gauge) and sends it to the Z-Wave Controller.

The Key is designed to be plugged into the USB Power Adapter. Module receives data for Temperature, Wind Chill, Velocity, Wind Gust, Wind Direction, Humidity, Rain Rate and Battery Level for each Sensor.

It is designed to act as repeater in order to improve range and stability of Z-wave network.

#### Package contents:

- Weather Station USB Key
- 2 x Thermo-Hygro Sensor
- Anemometer (Wind Sensor with Solar panel)
   Wind cups
  - Wind cups
  - Anemometer arm
  - Anemometer base
- 4 screws
- Rain Sensor
- Funnel shaped lid with battery hatch
- Sensor base
   Bucket see-saw mechanism
- Protective screen
- 4 screws

# Weather Station USB Key

#### Installation

- Connect the Weather Station Key into the USB
   Power Supply.
- Locate the module far from metal elements.
- Locate the module in the range of Z-Wave Network and in the range of all 433 MHz sensors.



S Service button (used to add or remove module from the Z-Wave network).
 I ED

#### LED Blinking Meaning

- LED is 1 second ON and 1 second OFF The module is in exclusion mode LED is ON The module is in inclusion mode LED Blinks 1 time fast The module received data from Thermo/Hygro Sensor Ch1 LED Blinks 2 time fast The module received data from Thermo/Hygro Sensor Ch2 LED Blinks 3 time fast The module received data from Wind Sensor LED Blinks 4 time fast The module received data from Rain Sensor Module Inclusion (Adding to Z-Wave network)
- Connect module to USB Power Supply
- auto-inclusion (works for about 5 seconds after connected to power supply) or
- enable add/remove mode on main controller

• hold service button **S** between 1.5 and 4 seconds NOTE: For auto-inclusion procedure, first set main controller into inclusion mode and then connect module to USB power supply.

# Module Exclusion/Reset (Removing from Z-Wave network)

- Connect module to power supply
- enable add/remove mode on main controller,
- hold service button **S** between 4 seconds and 8 seconds

By this function, all parameters of the module are set to default values, own ID is deleted and the module will include as unsecure next time.

If service button S hold more than 1.5 and less than 4 seconds module is excluded, but configuration parameters are not set to default values and the module will include next time as it was set into the Configuration Parameter 250.

#### Association

Association enables Weather Station module to transfer commands inside Z-Wave network directly (without main controller) to other Z-Wave modules.

#### Associated Groups:

- Group 1: Lifeline group (reserved for communication with the main controller), one node allowed. Group 2: basic on/off (triggered when the Wind Gust of the
- Wind Gauge exceed the Configuration Parameter 1 Value) up to 16 nodes.
- Group 3: basic on/off (triggered when the Rain rate exceed the Configuration Parameter 2 Value) up to 16 nodes. Endpoint 1: Thermo/ Hygro Sensor Ch1 – Temperature Group 1: Lifeline group, 0 nodes allowed. Endpoint 1 receives Temperature data from Thermo/
- Hygro Sensor on Channel 1. It is capable of receiving data in range of -199.0 °C and 199.0 °C. However, the operating temperature of the 433 MHz sensor is from -10 °C to 60 °C.

#### Endpoint 2: Wind Gauge – Direction

Group 1: Lifeline group, 0 nodes allowed. Endpoint 2 receives Direction data from Wind Gauge. The data is in range of 0.0° to 360.0°. Endpoint 3: Wind Gauge – Velocity

#### Group 1: Lifeline group, 0 nodes allowed.

Endpoint 3 receives wind speed data from Wind Gauge. It is capable of receiving data in range of 0.00 m/s to 88.00 m/s.

#### End point 4: Wind Gauge – Wind gust

Group 1: Lifeline group, 0 nodes allowed. Group 2: basic on/off (triggered when the Velocity exceed the Value of Configuration Parameter 1) up to 16 nodes. Endpoint 4 receives wind speed data from Wind Gauge. It is capable of receiving data in range of 0.00 m/s to 88.00 m/s.

#### End point 5: Wind Gauge - Temperature

Group 1: Lifeline group, 0 nodes allowed.

Endpoint 5 receives Temperature data from Wind Gauge. It is capable of receiving data in range of -199.0 °C and 199.0 °C. However, the operating temperature of the sensor is from -10 °C to 60 °C.

#### End point 6: Wind Gauge – Wind Chill

Group 1: Lifeline group, 0 nodes allowed.

Endpoint 6 receives Temperature data from Wind Gauge. It is capable of receiving data in range of -199.0 °C and 199.0 °C. However, the operating temperature of the sensor is from -10 °C to 60 °C.

### End point 7: Rain Sensor

Group 1: Lifeline group, 0 nodes allowed. Group 2: basic on/off (triggered when the Rain rate exceed the Configuration Parameter Value 2) up to 16 nodes. Endpoint 7 receives and calculates rain rate. The rain rate is in range of 0.00 mm/h and 300.00 mm/h.

#### End point 8: Thermo/ Hygro Sensor Ch1 – Humidity Group 1: Lifeline group. 0 nodes allowed.

Endpoint 8 receives Humidity data from Thermo/ Hygro Sensor on Channel 1. The data is in range of 0% and 100%.

# End point 9: Thermo/ Hygro Sensor Ch2 – Temperature

Group 1: Lifeline group, 0 nodes allowed. Endpoint 9 receives Temperature data from Thermo/

Hygro Sensor on Channel 2. It is capable of receiving data in range of -199.0 °C and 199.0 °C. However, the operating temperature of the sensor is from -10 °C to 60 °C.

### End point 10: Thermo/ Hygro Sensor Ch2 – Humidity

Group 1: Lifeline group, 0 nodes allowed. Endpoint 10 receives Humidity data from Thermo/ Hygro Sensor on Channel 2. The data is in range of 0% and 100%.

#### Configuration parameters

Parameter No. 1 – Wind Gauge, Wind Gust Top Value Available configuration parameter (data type is 2 Byte Dec):

- default value 1000 (10,00 m/s)
- 0 8800 = value from 0.00 m/s to 88.00 m/s if the Wind Gust is Higher than the Parameter Value, a device triggers an Association.

Parameter No. 2 – Rain Gauge, Rain Rate Top Value Available configuration parameter (data type is 2 Byte Dec):

- default value 200 (2,00 mm/h)
- 0 30000 = value from 0.00 mm/h to 300.00 mm/h if the Sensor Rain Rate is Higher than the Parameter Value, a device triggers an Association

#### Parameter No. 3 - Wind Gauge, Wind Gust

Available configuration parameter (data type is 1 Byte Dec):

- default Value 1
- 0 If the Wind Gust is Higher than the Parameter No.
  1 Value, then a Device sends Basic Set = 0x00.
- If the Wind Gust is Higher than the Parameter No.
   Value, then a Device sends Basic Set = 0xFF.)

#### Parameter No. 4 – Rain Gauge, Rain Rate

Available configuration parameter (data type is 1 Byte Dec):

- default Value 1
- 0 If the Rain amount is Higher than the Parameter No. 2 Value, then a Device sends Basic Set = 0x00.
- 1 If the Rain amount is Higher than the Parameter •
- No. 2 Value, then a Device sends Basic Set = 0xFF.) Unsolicited Report •

default Value 1

default Value 0

next step again to "1".

default Value 0

• 1 – Secure Inclusion

0 – Unsecure Inclusion

Key as secure follow the procedure:

to exclude the module

inclusion

Safety Procedure

chance of potential damage.

sensor values to extreme values.

Technical Specifications

Weather station

Weight

USB Kev

Dimensions (WxHxD)

Include the Key into the controller

LED on the module starts blinking

Set the parameter 250 to the value "1"

Dec):

•

1

2.

3

Δ

5

6

7.

8

9.

Dec).

0 - Unsolicited Report disabled

Parameter No. 15 - Random ID Enable

Available configuration parameter (data type is 1 Byte

If Random ID is disabled, the Weather Station USB Key

can receive data from multiple 433 MHz Sensors on the

same Channel. If the Random ID is enabled, the USB Key

can receive data from only one sensor on the same

channel. If the USB Key does not receive a data from a

sensor on a specific channel for more than 2.5 hours, it

clears the Random ID of the device and waits for a new ID.

If you replace the batteries in the modules, the Random ID

will change. If you want that the USB Key accept a module

immediately, set the Parameter No. 15 to "0" and in the

The Weather Station Key supports both, the secure and

unsecure inclusion. Even if the controller does not support

security command classes, the Key could be included as

unsecure and keep all the functionality.

By default, the Key includes as unsecure. To include the

Enable add/remove mode on main controller.

Unplug the module out of the power supply

enable add/remove mode on main controller

Now the module should be included as secure

The same procedure is to include the module as unsecure.

In the case of lost connection between the 433 MHz

Wireless Sensor and the Weather Station USB Key (more

than 15 minutes of lost connection), the module will set

-199.0 °C, Velocity = 88.00 m/s, Rain = 300.00 mm/h,

Humidity = 100 % or Direction =  $0.0^{\circ}$ ), so that the

associations and scenarios are triggered to lower the

If the Weather Station USB Key lose the power supply (or

any other reason reset the Key), the Key will not report

Sensor Values to the controller until new data is received

or maximum 240 seconds. If after 240 seconds, the Kev

still does not have new data from the sensor, it will set the

On each End point we can get battery level from

corresponding sensor. On the Root device is a battery

2 kg

460x120x430mm

level from the sensor with the lowest battery level.

Sensor values to extreme values. (Temperature =

Hold service button S between 1.5 and 4 seconds

If the exclusion of the module was successful, the

Plug the module into the power supply to star auto-

Parameter No. 250 - Unsecure / Secure Inclusion

Available configuration parameter (data type is 1 Byte

1 – Unsolicited Report enabled

0 - Random ID disabled

1 – Random ID enabled

If you enable Unsolicited Reports on the End Points, the USB Key will send data to the controller every time it receives data from the 433MHz sensors, which are different from the precious data.

Parameter No. 5 – End point 1 – Unsolicited Report Available configuration parameter (data type is 1 Byte Dec):

default Value 1

•

•

•

•

•

Dec).

.

Dec):

Dec):

Dec):

Dec):

Dec):

Dec).

.

٠

•

•

•

- 0 Unsolicited Report disabled
- 1 Unsolicited Report enabled

Parameter No. 6 – End point 2 – Unsolicited Report Available configuration parameter (data type is 1 Byte Dec):

- default Value 1
- 0 Unsolicited Report disabled
- 1 Unsolicited Report enabled

Parameter No. 7 – End point 3 – Unsolicited Report Available configuration parameter (data type is 1 Byte Dec):

Available configuration parameter (data type is 1 Byte

Parameter No. 9 - End point 5 - Unsolicited Report

Parameter No. 10 - End point 6 - Unsolicited Report

Parameter No. 11 - End point 7 - Unsolicited Report

Parameter No. 12 - End point 8 - Unsolicited Report

Parameter No. 13 - End point 9 - Unsolicited Report

Parameter No. 14 – End point 10 – Unsolicited Report

Available configuration parameter (data type is 1 Byte

default Value 1

- 0 Unsolicited Report disabled
- 1 Unsolicited Report enabled Parameter No. 8 – End point 4 – Unsolicited Report

0 - Unsolicited Report disabled

1 - Unsolicited Report enabled

0 - Unsolicited Report disabled

1 - Unsolicited Report enabled

0 – Unsolicited Report disabled

1 – Unsolicited Report enabled

0 - Unsolicited Report disabled

0 - Unsolicited Report disabled

1 - Unsolicited Report enabled

0 - Unsolicited Report disabled

1 – Unsolicited Report enabled

1 – Unsolicited Report enabled

Power supply	USB Power Supply, 5V DC
Operation temperature	-10 ~ +40°C
Distance to Z-Wave	up to 30 m indoors (depending on building materials)
Distance to 433Mhz Sensors	up to 100 m (depending on building materials)
Dimensions (WxHxD)	79x16x24mm
Electricity consumption	0,3 W

### 433MHz Sensors

Battery's	2 x UM-3 or "AA" size 1.5 V
Operation temperature	-10 ~ +60°C
Distance to USB Key	up to 100 m (depending on building materials)
Receiving Cycle	Remote Thermo/Hygro - Sensors cca. 45s Rain Gauge cca. 183s Wind Sensor cca.33s
Temperature Accuracy	+/-1°C or +/-2°F
Humidity Accuracy	+/-5%
Wind Speed Accuracy	+/- ( 2mph + 5% )
Wind Direction Accuracy	+/-11.25°

#### Z-Wave Device Class:

ZWAVEPLUS INFO REPORT ROLE TYPE SLAVE AL WAYS ON

GENERIC TYPE SENSOR MULTILEVEL SPECIFIC TYPE ROUTING SENSOR MULTILEVEL

#### Z-Wave Supported Command Classes:

COMMAND CLASS ZWAVEPLUS INFO V2, COMMAND CLASS DEVICE RESET LOCALLY V1 COMMAND CLASS MANUFACTURER SPECIFIC V2 COMMAND\_CLASS\_POWERLEVEL\_V1 COMMAND CLASS SECURITY COMMAND CLASS FIRMWARE UPDATE MD V2 Z-Wave Securely Supported Command

# Classes:

COMMAND CLASS VERSION V2 COMMAND CLASS SENSOR MULTILEVEL V7 COMMAND CLASS MULTI CHANNEL V4 COMMAND CLASS ASSOCIATION V2 COMMAND CLASS MULTI CHANNEL ASSOCIATION 1/3

COMMAND CLASS ASSOCIATION GRP INFO V2 COMMAND CLASS CONFIGURATION COMMAND CLASS BATTERY COMMAND CLASS MARK COMMAND CLASS BASIC

#### Endpoint 1, 2, 3, 4, 5, 6, 7, 8, 9, 10

#### Device Class:

ZWAVEPLUS INFO REPORT ROLE TYPE SLAVE AL WAYS ON

GENERIC TYPE SENSOR MULTILEVEL SPECIFIC TYPE ROUTING SENSOR MULTILEVEL

## Command Classes:

COMMAND CLASS ZWAVEPLUS INFO V2,

Securely Supported Command Classes: COMMAND CLASS VERSION V2 COMMAND CLASS SENSOR MULTILEVEL V7 COMMAND CLASS ASSOCIATION V2

COMMAND\_CLASS\_MULTI\_CHANNEL\_ASSOCIATION\_ V3 COMMAND CLASS ASSOCIATION GRP INFO V2

COMMAND CLASS BATTERY COMMAND CLASS MARK

COMMAND CLASS BASIC

This product can be included and operated in any Z-Wave network with other Z-Wave certified devices from any other manufacturers. All constantly powered nodes in the same network will act as repeaters regardless of the vendor in order to increase reliability of the network.

#### **Remote Weather Sensors**

The remote weather sensors include a thermo-hygrometer, anemometer (wind sensor) and rain sensor. All data collected by the sensors are transmitted to the Weather Station Key by wireless RF, with a range up to 100 meters (open area). The Weather station Key supports a maximum of 2 thermo-hygrometers, allowing 2 channels of temperature/humidity display (Ch1 and Ch2).

#### Setting up the Remote Weather Sensors

Before starting up the Weather Station Key, setup all the remote sensors first. When placing the sensors, make sure that they are within receiving range of the console unit.

Ideally, they should be within the line of sight of the console unit. Transmission range may be affected by trees, metal structures and electronic appliances. Test reception before permanently mounting your weather station.

Also make sure that the sensors are easily accessible for cleaning and maintenance.

The remote sensors should be cleaned on a weekly basis, since dirt and debris will affect sensor accuracy. Setting up the Thermo-Hygro Sensor(s)



1. Open the latch at the base of the thermo-hygro sensor. 2. Set the channel with a slide switch to Ch1 or Ch2 (Channel has to be selected before inserting a battery's) 3. Insert two 2 x UM-3 or "AA" size 1.5 V batteries.

4. Use a pin to press the "RESET" key which is in the battery compartment of thermo-hygro sensors after LED flach

5. Replace the latch and mount the unit at desired location. Placement Tips:

- The thermo-hygro sensor should be in an area with free air circulation and sheltered from direct sunlight and other extreme weather conditions. Place the unit in a shaded area, such as under a roof.

- Avoid placing the sensor near sources of heat such as chimneys.
- Avoid any areas which collect and radiate heat in the sun, such as metal, brick or concrete structures, paving, patios and decks.
- Ideally, place the sensor above natural surfaces such as a grassy lawn.
- The international standard height for measurements of air temperature is at 1.25m (4 ft) above ground level.

#### Setting up the Rain Sensor

1. Unlock the funnel-shaped top of the rain sensor by turning both knobs on the sides of the rain sensor in an anti-clockwise direction.

2. Lift the top off the base and insert two 2 x UM-3 or "AA" size 1.5 V batteries into the battery holder.

3. Replace the lid and secure into place by turning the knobs clockwise

4. Place the rain sensor in a location such that precipitation can fall directly into the sensor, ideally 2-3 ft above the ground. It may be secured into place by using the four screws provided.

5. The sensor must be accurately levelled for optimum cotton tips or pipe-cleaner. performance. To check if the sensor is levelled, remove the - Look out for spiders or insects that might have crawled lid and check if the ball bearing inside is at the midpoint of into the funnel. the leveller. Additionally, a bubble level or carpenter's level may be used.

6. Attach the protective screen onto the top of the lid. The screen will prevent any debris entering the sensor. Placement Tips:

- The rain sensor should be placed in an open area away from walls, fences, trees and other coverings which may either reduce the amount of rainfall into the sensor, deflect the entry of wind - blown rain, or create extra precipitation runoff. Trees and rooftops may also be sources of pollen and debris.

- To avoid rain shadow effects, place the sensor at a horizontal distance corresponding to two to four times the height of any nearby obstruction.

- It is important that rain excess can flow freely away from the sensor. Make sure that water does not collect at the base of the unit

- The rainfall measurement mechanism utilizes a magnet; hence do not place any magnetic objects around the proximity of the sensor.

#### Setting up the Anemometer (Wind Sensor)

1. Assemble the wind cups and wind vane to the anemometer arm

2 Attach the assembled anemometer to the base

3. Insert two 2 x UM-3 or "AA" size 1.5 V batteries into the battery holder in the base and connect the second battery to the solar nanel connector

4. Mount the anemometer onto a vertical surface, using the fittings provided.

#### Placement Tips:

- Check that wind can travel freely around the anemometer and is not distorted by nearby buildings, trees or other structures

- For better results, place the anemometer at least 3 m above local structures and obstacles. The ground creates a frictional effect to wind flow and will attenuate readings. - Aim for maximum exposure of the anemometer to the commonest wind directions in your area.

- The official mounting location for anemometers is 10m (33 ft) above ground level in a clear unobstructed location. Maintenance

Changing Batteries

The battery statuses of the sensors are checked every hour. If the low battery indicators light up, replace the batteries for the corresponding unit immediately.

#### **Changing Batteries for the Remote Sensors**

1. Replace the batteries following the setup instructions for the corresponding sensor.

2. When the batteries are properly installed, the sensor will resume sending signals to the main console unit. Cleaning

#### The Weather Station Key and outer casings for the remote sensors can be cleaned with a damp cloth. Small parts can be cleaned with a cotton tip or pipe-cleaner.

Never use any abrasive cleaning agents and solvents. Do not immerse any units with electronic parts in water or under running water.

#### Anemometer

- Check that the wind vane and wind cups can spin freely and are free from dirt, debris or spider webs.

#### Rain Sensor

Like all rain gauges, the rain sensor is prone to blockages due to its funnel shape. Checking and cleaning the rain sensor from time to time will maintain the accuracy of rain measurements.

- Detach the protective screen and lid. Remove any dirt, leaves or debris by cleaning the items with soapy water and a damp cloth. Clean small holes and parts with a

- Also clean the swinging mechanism with a damp cloth. Troubleshooting

The Weather Station Key will not receive any data when the wireless link with the Sensor is lost.

Check or replace the batteries for the corresponding sensor

If the above does not solve the problem, check the wireless transmission path from the corresponding sensor to the main console unit and change their locations if nocossany

Although wireless signals can pass through solid objects and walls, the sensor should ideally be within the line of sight of the console unit

The following may be the cause of reception nrohlems

- Distance between remote sensor and Weather Station Key is too long. (Maximum transmission distance in open area conditions is up to 100 m.)

- Signal shielding materials such as metal surfaces. concrete walls or dense vegetation in the path of transmission

- Interferences from wireless devices (such as cordless phones, radio headsets, baby listening devices) and electronic appliances.

The weather readings do not correlate with measurements from TV, radio or official weather renorts

Weather data can vary considerably due to different environmental conditions and placement of weather sensors.

Check the placement tips included in this manual to site your sensors in the best possible way. PRECAUTIONS

This product is engineered to give you years of satisfactory service if you handle it carefully. Here are a few precautions

1. Do not immerse the unit in water.

2. Do not clean the unit with abrasive or corrosive materials. They may scratch the plastic parts and corrode the electronic circuit.

3. Do not subject the unit to excessive force, shock, dust, temperature or humidity, which may result in malfunction. shorter electronic life span, damaged battery and distorted narts

4. Do not tamper with the unit's internal components. Doing so will invalidate the warranty on the unit and may cause unnecessary damage. The unit contains no userserviceable parts.

5. Only use fresh batteries as specified in the user's manual. Do not mix new and old batteries as the old ones may leak.

6. Always read the user's manual thoroughly before operating the unit.

#### CAUTION

- The content of this manual is subject to change without further notice.

- Due to printing limitation, the units shown in this manual may differ from the actual units.

- The contents of this manual may not be reproduced without the permission of the manufacturer.

This user manual is subject to change and improvement without notice.

NOTE: User manual is valid for module with SW version S2 (SW version is part of P/N)! Example: P/N: ZMNHZDx Hx**S2**Px

#### Important disclaimer

devices using scenarios or associations.

disposal at least for free of charge.

Warning!

Z-Wave wireless communication is inherently not always 100% reliable, and as such, this product should not be used in situations in which life and/or valuables are solely dependent on its function.

As well, Weather Station Sensors can lose communication

with the Weather Station Key. The caution should be taken

when using the data from the sensors for controlling other

Do not dispose of electrical appliances as unsorted

Contact your local government for information regarding

the collection systems available. If electrical appliances

are disposed of in landfills or dumps, hazardous

substances can leak into the groundwater and get into the

food chain, damaging your health and well-being. When

replacing old appliances with new once, the retailer is

legally obligated to take back your old appliance for

This device complies with part 15 of the FCC Rules.

Operation is subject to the following two conditions:

(1) This device may not cause harmful interference, and

including interference that may cause undesired operation

NOTE: This equipment has been tested and found to

comply with the limits for a Class B digital device, pursuant

to part 15 of the FCC Rules. These limits are designed to

provide reasonable protection against harmful interference

in a residential installation. This equipment generates,

uses and can radi-ate radio frequency energy and, if not

in-stalled and used in accordance with the instructions.

may cause harmful interference to radio communications.

However, there is no guarantee that interference will not

occur in a particular installation. If this equipment does

cause harmful interference to radio or television reception,

which can be determined by turning the equipment off and

on, the user is encouraged to try to correct the interference

-Increase the separation between the equipment and

-Connect the equipment into an outlet on a circuit

-Consult the dealer or an experienced radio/ TV

Qubino

5250 Solkan

Date: 18.10.2016

user manual V1.2 eng

Slovenia

Tel·

Web:

Goap d.o.o. Nova Gorica

Ulica Klementa Juga 007

E-mail: info@gubino.com

+386 5 335 95 00

www.qubino.com

Document: Qubino Weather Station

different from that to which the receiver is connected

by one or more of the following measures:

receiver

technician for help.

-Reorient or relocate the receiving antenna.

(2) this device must accept any interference received,

municipal waste, use separate collection facilities.